Flexibility Through Rule and Policy

Charlotte, NC May 16, 2001 Gabrielle Stevens



Goals Are Key

- ◆ Protect the environment
- Ensure the emissions "commodity" is measurable
- ◆ Minimize cost of data collection
- ◆ Reduce administrative burden
- ◆ Continuously improve program functioning



This Year's Activities to Address Goals

- ◆ Part 75 Proposed Rule Revisions
 - Simplify compliance by removing obsolete sections
 - Increase flexibility for missing data periods, bypass stacks, and LMEs
 - Improve previously identified areas that needed change



This Year's Activities to Address Goals

- Policy Decisions
 - Analyzers
 - Fuel Flow-to-load
 - Quality Assurance
- New Tools
 - Flow methods



Proposed Rule Changes: Missing Data

- New option allowing the use of fuel-specific missing data
- New option for add-on control units allowing controlled or uncontrolled missing data substitution based on control operating status



Proposed Rule Changes: Missing Data, continued

- ◆ Remove all references to outdated CO₂ missing data routines
- ◆ Add non-load based missing data procedures for units that do not produce electrical or thermal output (e.g., cement kilns, process heaters)



Proposed Rule Changes: Bypass Stacks

- ◆ Option to report fuel-specific maximum values instead of monitoring bypass stack
 - -Allows use of MPC (maximum potential concentration) for SO₂ and CO₂
 - -Allows use of NOx MER (maximum potential emission rate)
 - -Allows use of MPF (maximum potential flow)

Proposed Rule Changes: LMEs

- Clarify qualification, certification, and reporting requirements
- ◆ Allow turbines with water injection, waterto-fuel injection, or steam injection to use tested defaults below 0.15 lb/mmBtu
- ◆ Allow uncontrolled diffusion flame turbines to correct fuel- and unit-specific NOx emission rates to standard conditions



Proposed Rule Changes: LMEs, continued

- ♦ Allow single-load testing for units that operate at one load level $\geq 85\%$ of the time
- ◆ Allow single load testing for turbines which operate at a predetermined temperature
- Allow base-load testing for peaking turbines used primarily at base load



Proposed Rule Changes: Subpart H

- Expand and clarify the missing data procedures and QA requirements for sources that report data only during the ozone season
- ◆ Lay out protocols for ozone season (rather than the calendar year) compliance period
- ◆ Instructions added to EDR v.2.1 for ozone season only reporting



Proposed Rule Changes: Appendix D

- Clarify missing data routines and how/when to do sampling
- ◆ Put fuel characterization on a total Sulfur basis (vs. H₂S)
- ◆ Add equation for calculating unit heat input rate when multiple fuels are combusted



Proposed Rule Changes: Appendix E

- Revise missing data procedures
- ◆ Revise retesting frequency to once every 20 calendar quarters (5 years) for all fuels
- ◆ Add instructions on what to report when actual heat input exceeds maximum HI on correlation curve; or NOx controls are not operating or out of acceptable ranges



Policy on Like-Kind Replacement Analyzers

- Section 7 of Policy Manual
- We now allow use of like-kind replacement gas analyzers, provided:
 - Limited to 720 hours a year
 - Perform linearity when you bring it on-line
 - Use the same monitoring system ID but different component ID



RT 510

Status	Sys ID	Sys Param	Comp ID	Comp type
U	101	SO2	211	SO2
A	101	SO2	LK1	SO2
U	101	SO2	999	DAHS



Policy on Dual Range Analyzers

- Section 10 of Policy Manual
- ◆ Allows averaging 200% of MPC for spikes with real low-range data when using default high range option
- ◆ Flag in EDR with MODC of 19
- ◆ Same concept for overscaling going off the high range: can average spike with hourly data



Policy on Use of Mid-Level Cal Gas

- ◆ Section 10 of Policy Manual
- Provides flexibility to use high or mid-level cal gas for daily cals - your choice
- ◆ DAHS needs to flag it properly with H or M in Record Type 230



Policy on Electronic QA Plans

- Policy says QA Plans may be stored electronically if you can produce them on request by an auditor or inspector
- ◆ Saves paper and space
- ◆ Currently the rule allows for monitoring plans information to be stored electronically so we're going the next step
- ◆ Rule revisions will finalize



Policy on Fuel Flow to Load Test

- Section 25 of Policy Manual
- Optional quarterly test to extend QA on fuel flow meters for up to 5 years
- Not a requirement but can lessen QA frequency and allows us to feel confident meter is reading accurately on a quarterly basis



Policy on Appendix E Missing Data

- Section 26 of Policy Manual
- ◆ Previously, when HI rate is above maximum rate on correlation curve, use one of two options: linear extrapolation or the MER, whichever is highest
- ◆ Now allow 1.25 times the highest NOx point on the correlation curve (which should be less conservative)



Software for Flow Test Methods 2F, 2G, and 2H

- ◆ Policy Manual Questions 3.26-3.35
- Developed new software that helps do calculations and puts data in EDR format
- Can manually enter data on site when doing testing
- Visit our booth for a live demonstration!



Coming Soon (Stay Tuned!)

- Recertification Events Policy
- Searchable Policy Manual
- Electronic Policy Newsletter
- ◆ Turbine Policy Initiative



Clean Air Markets Website

www.epa.gov/airmarkets

